

SPECIFICATIONS - DETAILED PROVISIONS
Section 15058 - Cast Iron Fittings

C O N T E N T S

PART 1 - REQUIREMENT	1
1.01 CAST IRON FITTINGS	1

**SECTION 15058
CAST IRON FITTINGS**

PART 1 - REQUIREMENT

1.01 CAST IRON FITTINGS

- A. Cast iron flanged fittings shall conform to the latest revision of ASA Spec. A-21.10 (AWWA C-110) flanged fittings. These fittings shall be cement lined in accordance with the latest revision of ASA Spec. A21.4 and shall have standard machine finish.
- B. Cast iron hub fittings shall conform to the latest revision of AWWA C100-52 ASA 21-10-250 p.s.i. for Class 150 and 200 pipe, designed for use with pressure pipe except as otherwise specifically stated elsewhere. These fittings shall be cement lined in accordance with the latest revision of ASA Spec. A21.4.

Size, joint type, and pressure rating (150 or 250 p.s.i.) shall be as specified on purchase order or shown on construction plans and bid sheet.

END OF SECTION 15058

[PAGE LEFT INTENTIONALLY BLANK]