



PLAN



DETAIL


FORMED SEALANT GROOVE DETAIL

NOTE: AT CONTRACTORS OPTION GROOVES MAY CONTINUE STRAIGHT ACROSS CONSTRUCTION JOINT INTERSECTIONS OR BE STAGGERED AS SHOWN IN PLAN.



TYPICAL CRACK REPAIR DETAIL

NOTE: PRIOR TO FILLING STRUCTURE WITH WATER REPAIR ALL CRACKS IN FLOOR SLABS, WALLS, AND ROOF SLAB AS PER DETAIL ABOVE.

REVISIONS				APPROVALS				EASTERN MUNICIPAL WATER DISTRICT STANDARD DRAWING	
NO.	DATE	INITIAL	DESCRIPTION	APP'D	DATE	INITIAL	DATE		
Δ	8/26/97	CRD	REDRAWN A-533 ON CAD	VJB	1/28/98	JVS	3/3/87	 <p>EASTERN MUNICIPAL WATER DISTRICT</p>	
Δ	3/12/01	GR	REVISED FILE ID NO						
REFERENCES: SUPERCEDES A-533				SCALE: NONE				<p>APPROVED <i>James H. Burt Jr.</i> 4/8/87</p> <p>ASSISTANT GENERAL MANAGER ENGINEERING DATE</p>	
FILE I.D.: m:\graph\oa\water\maint\standard.dwg\B-666.dgn				DRAWN BY CRD					
								B-666	