

**UPDATE LOG FOR SECTION 02513**

Date	Item(s) Changed	Page #
08/25/08	<p><b><u>PART 2 – PRODUCTS</u></b></p> <p>2.01 <b>AGGREGATE</b> BASE COURSE  <del>Provide base material, spread, and compact to 95% minimum. Base material shall be class 2 base conforming to specifications of Riverside County Transportation Department and is to be approved by the Engineer prior to delivery to the site.</del>                      Aggregate Base Course shall be Class II aggregate base. The aggregate base course shall be the thickness shown on the plans and shall be placed in maximum 4" lifts. Aggregate base course shall be compacted to 95% of maximum compaction, as specified by ASTM D-1557. Aggregate base course shall be furnished, spread and compacted, as specified for Class II Aggregate Base Course in the Standard Specifications, State of California, Department of Transportation, latest edition. A spreader box will not be required but care shall be taken to prevent segregation during placement.</p> <p>2.02 ASPHALT CONCRETE                      Asphalt concrete shall conform to the requirements of Caltrans Standard Specifications Section 39, for Type "B". Aggregate will conform to a grading for ½" maximum aggregate with paving grade asphalt <del>PG-70-10</del> <b>PG 64-10</b> (Section 92) unless otherwise directed by the Engineer.</p> <p>2.04 PRIME COAT  <del>Prime coat shall be SC-250 liquid asphalt conforming to the requirement of Caltrans Standard Specification Section 93, only when specifically required on the plans or specifications for a project.</del>                      When indicated on the Plans or in the Special Provisions, a prime coat consisting of Grade SC-250 liquid asphalt shall be applied in accordance with Caltrans Standard Specification Sections 39 and 93.</p>	1 & 2
02/22/08	<p><b><u>PART 2 - PRODUCTS</u></b></p> <p>2.02 ASPHALT CONCRETE                      Asphalt concrete shall conform to the requirements of Caltrans Standard Specifications Section 39, for Type "B". Aggregate will conform to a grading for 1/2" maximum aggregate with paving grade asphalt <del>AR-4000</del> <b>PG 70-10</b> (Section 92) unless otherwise directed by the Engineer.</p> <p>2.03 ASPHALT BINDER                      Asphalt binder to be mixed with aggregate shall be paving asphalt <del>AR-4000</del> <b>PG 70-10</b> or liquid asphalt (Section 93) in accordance with Caltrans Standard Specifications 39, 92, and 93. Paving asphalt to be mixed with aggregate shall be steam-refined asphalts.</p>	1 & 2

**Legend:**

**Added**

~~Strike-out~~

**Document is prepped for double-sided printing**

**Start your Print Range parameter @ page 3 for printing (or discard first 2 pages)**